Application Submittal						
Date:						
Type	of Review &					
Authorization Needed:		Design Review	Site Plan	Public Works	Structural Review	
(Circle	e One)					
	operty Owner - Pro wner:	rty Owner - Project Information: r: Reynolds				
Jo	b Address:	469 Greys River Loop Road				
l l	escription of oject:	Deck Replacement				

Authorization to Proceed:

Authorization Completed By:	Dee J. Rammell		
Status of Authorization:		<u>Approval</u>	

Notes:

- 18" minimum eave overhang to be maintained
- Town of Alpine Land Use and Development Code dictates a ground snow load of 143 psf. Resubmission not needed.

Permit Issuance:

Town Clerk:		Date:
Signature		