



Element Plumbing, INC  
 PO Box 11302  
 Jackson, WY 83002

**BILL TO**

Paul Baker  
 399 Columbine Street  
 Alpine, WY 83128 USA

INVOICE  
 39507175

INVOICE DATE  
 Nov 11, 2025

**JOB ADDRESS**

Paul Baker  
 399 Columbine Street  
 Alpine, WY 83128 USA

Completed Date: 11/11/2025

Technician: Dwaine Douglas

Payment Term: Due Upon Receipt

Due Date: 11/11/2025

**DESCRIPTION OF WORK**

Arrived on site for sewer main clog. Found sewer line clogged from clean out to street. Will cable sewer main and then camera to locate issues. Unable to clear and recommend hydro jet with van and re camera line. Returned to hydro jet sewer main line from clean out in back yard. Ran hydro jettter up to 104'ft and cleared line Arnica Trail Street side. Then camera sewer line and found from 91'ft to 108'ft belly in line with major separation. Line at lateral may need to be dug up in street and replaced.

TASK	DESCRIPTION	QTY
CBL-100	Attempt to clear your main drain from an outside access point using an electric snake.	1.00
EVAL-100	Evaluate the condition of your Main/Branch Line using a video recording camera through an existing access point.	1.00
Custom	<u>Hydro jettter van</u>	1.00

SUB-TOTAL \$2,115.98

TAX \$0.00

TOTAL DUE \$2,115.98

BALANCE DUE \$2,115.98

Thank you for choosing Element Plumbing