



AGENDA ITEM SUMMARY FORM

MEETING DATE: January 25, 2022

PREPARED BY: Chris Whittaker

AGENDA CONTENT: Discussion and possible action on a bid proposal for lift station #8 improvements.

AGENDA ITEM SECTION: Regular Agenda

BUDGETED AMOUNT:

FUNDS REQUESTED: \$338,150.00

FUND:

EXECUTIVE SUMMARY:

The City of Angleton's LS #8 sanitary sewer collection system is a 15" truss pipe that has reached its life expectancy. The City has recently performed a large point repair on this line due to a major collapse and the remaining portion of this line is in need of replacement as soon as possible. The existing sanitary sewer line is under the existing sidewalk and will require its replacement also as part of this project. Also, several manholes are compromised and will require replacement. The existing wet well of LS #8 will be rehabilitated with cementitious wall liner to rebuild the walls of the lift station. The electric service will be reset to allow easier access to the site.

On January 18, 2022, the City received two bids on this project. The low bid was for \$338,150.00 (\$296,250 being the Base Bid & \$41,000 being supplemental items). The Low Bidder is HTI who has performed many emergency repairs throughout the City and performed the previous repair to LS #8 sanitary sewer line.

RECOMMENDATION: Accept the bid for \$338,150.00 from HTI for the repair to LS #8 and its Sanitary gravity sewer.