



AGENDA ITEM SUMMARY FORM

MEETING DATE: November 12th, 2024
PREPARED BY: Hector Renteria
AGENDA CONTENT: TCEQ Compliance Investigation Update
AGENDA ITEM SECTION: Regular Agenda

BUDGETED AMOUNT: N/A **FUNDS REQUESTED:** N/A

FUND:

EXECUTIVE SUMMARY: On October 16th, 2024, TCEQ scheduled a comprehensive compliance investigation for the Angleton Wastewater Treatment Plant. This investigation resulted in several alleged violations (AV). These AV's required corrective action to resolve, which were all fulfilled in the time frame allotted. Now that this has been submitted, we will await TCEQ response, and how they proceed forward. This investigation was not directly tied to the EPA's compliance order we received on May 16th, 2024, however there were observations in both instances that stem from the same root cause, low dissolved oxygen. In the EPA's compliance order there were instances of high ammonia. In TCEQ's investigation low dissolved oxygen was recorded. Without enough dissolved oxygen the ammonia cannot be removed from the wastewater. As we move forward with our capital improvement project at the wastewater treatment plant, these ongoing issues will be corrected.

RECOMMENDATION: This is only an informational item.