Existing - Current Water System						Proposed - In Design or Construction (Freedom Park and Southside EST)		Total Surplus Connections (Existing	Proposed - Change Boosters at Plant #3 to 3- 1,000 GPM (Discussed end of May 2021)		Total Surplus Connections
Facility Type	Total Capacity	TCEQ Criteria	Min. Requiremen t	Surplus	Additional Connections	Capacity Increase	Additional Connections	+ proposed)	Capacity Increase	Additional Connections	(Existing + proposed)
Booster Pumps	5,100 gpm	110 Gal/Capita/d ay 3 person/Con n. 2.125 PHF	4,290 gpm	810 gpm	1,662	750 gpm	1,540	3,200	300 gpm	615	3,815
Total Storage	3,450,000 Gal	200 Gal/Connect ion	1,762,000 Gal	1,688,000 Gal	8,440	300,000 Gal (250,000+ 50,000)	1,500	9,940			9,940
Elevated Storage	1,000,000 Gal	100 Gal/Conn.	881,000 Gal	119,000 Gal	1,190	250,000 Gal	2,500	3,690			3,690
Water Supply	4,100 gpm	0.37 gpm/conn.	3,260 gpm	840 gpm	2,270	1,000 gpm	2,700	4,970			4,970

Total City Connections (base): 8810

		Additional Connections Available based on	3690
Additional Connections available based on limitation from Booster Pump Capacity =	3200	limitation from Elevated Storage Capacity =	
Identified connections in "INTERNAL Summary" tab =	2197		2197
Remaining connections available =	1003		1,493
		/// //	

(limited by Elevated Storage Capacity)