



August 16, 2024

Mr. Otis Spriggs  
Director of Development Services  
City of Angleton  
121 S. Velasco  
Angleton, TX 77515

Re: On-Going Services  
Construction Plans for Coral Haven Street Dedication, Street Dedication 3, and  
Phase 1a Offsite Utilities – 4<sup>th</sup> Submittal Review  
Angleton, Texas  
HDR Job No. 10391496

Dear Mr. Spriggs:

HDR Engineering, Inc. (HDR) has reviewed the construction plans for the above referenced subdivision and offers the following comments:

Construction Plans

1. Sheet 27 of 37 – BASELINE C – STA. 0+00.00 to STA. 1+49.30 - Baseline C - Update plan and profile to show water line improvements. Please resubmit a final planset once this revision has been completed.
2. The storm pipe material within the planset was previously designed using reinforced concrete pipe and has changed to "HP Storm Pipe" with the most recent submittals. Request for the use of this pipe material alternative was recently coordinated through the City in which use of the pipe would be allowed subject to the installation being performed per standard specifications designated by TxDOT. A formal request shall be made in writing for use of the pipe in other concurrent and future sections within the subdivision.

HDR takes no objection to the proposed Coral Haven Street Dedication, Street Dedication 3, and Phase 1a Offsite Utilities with the exceptions noted. Please note, this does not necessarily mean that the entire drawings, including all supporting data and calculations, has been completely checked and verified; however, the drawings and supporting data are signed, dated, and sealed by a Professional Engineer licensed to practice in the State of Texas, which therefore conveys the engineer's responsibility and accountability.

If you have any questions, please feel free to contact us at our office (713)-622-9264.

Sincerely,

HDR Engineering, Inc.

Javier Vasquez, P.E., CFM  
Civil Engineer

cc: Files (10391496 /10361761)

Attachments