

RESOLUTION 25-21

APPROVAL OF THE CITY COUNCIL OF THE CITY OF ANGELS TO ADD THE FOOTHILL VILLAGE WATER SUPPLY PROJECT TO THE APPROVED FIVE-YEAR (5-YEAR) WATER-WASTEWATER CAPITAL IMPROVEMENT PROJECT LIST WITH THE PROJECT SCHEDULING FOR THE 2025-2026 FISCAL YEAR

WHEREAS, the Foothill Village Senior Living Center (Foothill Village) is supplied water via a 10-inch pipeline which is part of the water distribution system that delivers water to the Stelte subdivision, north of Vallecito Road; and

WHEREAS, the distribution system receives water from a high pressure, 10-inch transmission pipeline connected to the 16-inch transmission main from the City Water Treatment Plant; and

WHEREAS, because of high pressures in the 10-inch transmission main, water is routed through a pressure reducing station prior to entering the distribution system for the Stelte subdivision; and

WHEREAS, if the pressure reducing station were bypassed, resulting pressures in the distribution system could damage water services/plumbing within the service area; and

WHEREAS, Foothill Village is located approximately 110 ft above the Stelte subdivision; and

WHEREAS, because of this elevation differential, water delivery pressures are low at Foothill Village; and

WHEREAS, during the peak summer demand period, water service to the upper floors of the senior living center has become problematic; and

WHEREAS, to resolve this issue and to help meet fire flow requirements at Foothill Village, an alternate water supply line is necessary; and

WHEREAS, specifically, a connection to the 10-inch transmission main upstream of the existing pressure reducing station and construction of an 8-inch waterline is recommended; and

WHEREAS, as illustrated in the attachment, the 8-inch pipeline would be routed within private property just north of the Stelte subdivision and connected to the 10-inch pipeline in Dutsch Court; and

WHEREAS, a valved interconnection would be installed at that location to avoid over-pressuring the Stelte subdivision water distribution system should water be back fed into the distribution system; and

WHEREAS, construction of the recommended 8-inch waterline would require acquisition of right of entry from the property owner (Richard Roller) and a permanent 20-ft wide easement for future access for maintenance.

NOW THEREFORE BE IT RESOLVED by the City Council of the City of Angels, the City Council approves to add the Foothill Village Water Supply Project to the approved five-year (5-year) Water-Wastewater Capital Improvement Project (CIP) List with the project scheduling for the 2025-2026 Fiscal Year.

AYES :
NOES :
ABSENT :
ABSTAIN :

Michael Chimento, Mayor

ATTEST:

Rose Beristianos, City Clerk



HOME OF THE JUMPING FROG