

City of Aniak
CITY COUNCIL SPECIAL MEETING
Teleconference
Wednesday, March 04, 2026 at 2:30 PM

AGENDA

Virtual Meeting Information:

To Participate please call 1-800-315-6338
Conference Code- 54481#

- I. Call to Order @ 2:41pm**
- II. Roll Call-** D.Bonanno-P , L.Seavey-P , A.Morgan-A , C.Morgan-P , S.Charles-A , A.Folz P, B.Morgan A
Staff- L.Kameroff-P , C.Phillips-P , M.G.Morgan-A , F.Vaska- A
- III. Old Business**
- Preliminary Engineering Reports @ 65% for Selection of Water & Wastewater Alternatives 1-4 options- Dave read over the resolution for the City of Aniak to Indicate the preferred water and wastewater alternatives for advancement in the preliminary engineering report. Open discussion: 4 has alternate 2 and 3 for water. Laurie sent a PDF and work document to alternate or add to it. CMorgan- asked if the piped water would be above ground or will it be buried. Suggested to do it by sections for piped water. Alternative 1 would be the more pricier option. Public comments- Leslie Boelens emailed “Aniak is on ideal ground for personal wells. Please put resources toward fixing and maintaining and putting in new wells. A piped water system should the table. People don’t want high water bills. A city well in unnecessary. In addition to the community hall there are other private sources of water for filling containers. Making it easier to fix currents wells is the best solution. Watering point by city will it be for community to pack water. Emily Peterson asked if the station that will be possibly put in by the city for residents to pack water instead of the Community Hall and Clinic? The community point will be for water trucks and residents to pack water. A. Folz asked how would are we going to pay. Laurie Hulse said additional fees would be added or increase. CMorgan asked who is going to bring in the person to pound in the well. Laurie Hulse said that the new wells will be modern drilled will. The new wells will be 80-100 feet deeps and will be tested as they drill. LKameroff said that the community wasn’t probably aware of the water project. More houses probably need assistance that weren’t surveyed. Laurie Hulse said that council should appoint someone to work on the remaining surveys. There is a deadline for this 3-4 weeks. City staff will work on getting it out there and surveyed to get an accurate number of homes that may need assistance. Utilize the customer list and contact when we figure out which homes will need to be surveyed. Will also post a public notice. D. Bonanno read the Wastewater alternatives. Council is leaning for Alt. 2. Laurie Hulse said not many disadvantages- the lagoon will be a little larger and closer to the river by 50 feet. A Folz said then we don’t have to worry about erosion since it is going to be 50 feet away from the river. LKameroff said that the new lagoon design will have a Levee built around it. A. Folz supports Alt.2 for wastewater. Council doing roll call vote to approve wastewater Alt 2: L. Seavy aye, C. Morgan Aye, A.Folz Aye, D. Bonanno Aye. Motion passed to accept Alt 2 for wastewater. Motion to table the water system to our next regular meeting: CMorgan made a motion. Was 2nd by L. Seavy. Motion passed.
- IV. Time and Place of Next Meeting-** March 18, 2026 6pm
- V. Adjourn** A motion was made by C.Morgan to adjourn the meeting. 2nd by A. Folz. Meeting adjourned @ 3:39pm

Attested:

Mayor David Bonanno *Date*

City Clerk/Treasurer Charlotte Phillips *Date*