

## **Superintendent Report**

Worked on permits.

Attended a Planning Commission Meeting.

Received bids to work on M.H. truck (leaking intake manifold gasket.

Worked in the front office taking payments and answering the phone multiple days.

Studying Cross Connection Control Regulations.

Contacted the construction company responsible for cleaning up the demo at 112 S. Jennings. (alley North of Pronto)

## **Electric Dept.**

Set up Santa House.

Worked on Transformer Recycling list.

Replaced light bulbs at Police Station.

Cut down tree at 601 N. Anthony.

Received 3 pad mount transformers.

Daniel and Garret went to McPherson for Transformer Connection Training.

Worked on #16 Bucket Truck. Broken shift tube.

Had an outage 7.5 miles west and 1 mile south. Cause was from wildlife.

Unloaded hardware from Border States.

Work Orders

Light List Locates.

Turn On/Off Orders

Just Read Orders

## **Street Dept.**

Installed new street signs.

Snow removal.

Ice sanding.

Grading roads.

Worked on some roads and alleys.

Cut a few trees

### **Water Dept.**

Pulled lake pump.

Replaced Mc D's lift station suction flange.

Replaced the starter on # 5.

Started on old hospital manhole repair.

Started work on Vulcan press at the sewer plant.

Worked on Well #5 check valve. Need to order.

Cleaned well house 1, south shop, and Water Plant chlorine room

### **Power Plant**

No Report