

Department Reports

4.11.2025

ELECTRIC DISTRIBUTION

Tickets, locates

Cut down trees on tree list.

Replaced siren batteries on West Hays.

Installed water pump in lake for Golf Course.

Attended Heartland Metering Conference.

Report of outage on N. Springfield. Cause from wildlife.

POWER PLANT

Rounds

Guys have been keeping up service work on cop cars and fire trucks.

Meter readings and training BD to be backup person to NC.

NC went up to meter school to gather information on AMI meters for a future project.

Had a few days where SPP stepped up grid reliability issues because so many base load units are down for maintenance and the wind has been really unreliable.

Been spending a tremendous amount of time picking up limbs with all the dead trees and the wind lately. Mowing and more mowing at the lake and the power plant.

Been trying to control stickers at the dog park , work in progress for sure.

Got the volleyball courts and swimming area sand all tilled up nicely and nets hung up for the summer.

Had some maintenance issues in the containment pits in the 138 substation and will be getting that fixed back normal soon.

Normal maintenance at the plant and substations , training and non stop mowing.

STREET

Grading

Mowing

Ran sweeper on Garfield and S Anthony

Cut trees on N Lincoln, N Franklin, N Springfield, W Ironton, S Madison

WATER/WASTEWATER

Rounds, tickets, locates

Work on pool plumbing and cleaning

Prime McDonalds lift station

Meeting with engineers