

November 17, 2023

Earl Mies
Mies Construction, Inc.
1919 SW Blvd.
Wichita, Ks 67213

RE: Harper County Growth Initiative 2022 BASE Grant Project
Sunrise 2nd Addition, Anthony, Kansas

Mr. Mies,

Based on failed concrete tests conducted on the low cement concrete placed in the Sunrise 2nd Addition portion of the 2022 BASE Grant Project, it was determined that the concrete did not meet project specifications. The low cement concrete which was placed in the construction of curb and gutter and pavement, placed between October 11, 2023 and November 2, 2023, will have to be removed and replaced.

The City of Anthony is in agreement with this decision.

Sincerely,



Joel Krossschell, P.E.
EBH Engineering
JoelK@EBHengineering.com
620-855-7030