

Superintendent Report

Worked up front in the office taking payments and answering the phone.

Worked on a few permits.

Filed a sign variance with the county.

Printed locates for Electric and Water

Electric Dept. Report

Attended KMU Safety Meeting.

Delivered Door Knockers

Replaced service pole at Spring Grove Cemetery.

Had power outage in N.E. Rural. Cause from wildlife.

Tightened primary 4 miles east and 1 mile north.

Replaced batteries on truck #1.

Looked at possible new service 7 miles north and 2 .2 miles east.

Took down service at 586 E. Hwy 44

Wired up motor at waste treatment plant.

Cut down 2 trees in the east park.

Worked on 2 quotes for new services.

Hung new meter loop at 405 N. Jennings

Fixed cross arm 3 miles north 2.5 miles west.

Turn On/Off Orders

Fixed lights on light list.

Just Read Orders

Locates

Street Dept. Report

Regular grading of town and lake.

Street sweeping.

Hauled sweepings to east landfill.

Hauled dirt and sand to the lake to fill low spots.

Cut trees in town on the tree list (15 cut down so far around 15 left to cut). We will grind the stumps this year when all of the trees are down.

Street signs (all green signs have been replaced, we will put up posts and new signs when the streets at Sunrise 2 are finished.

Worked on alleys at Jennings and Garfield, Jennings and Grant, and one off of Steadman.

Power Plant/ Lake Report

None – Larry off

Water/Wastewater Dept. Report

None- Matt off