

SUPERINTENDENT REPORT

December 19, 2023

Superintendent Report

I have been working in the front office taking utility payments, answering the phone, and doing whatever else I can to help while short-handed.

Have gotten tire quotes for a couple of electric dept. vehicles.

Several permits.

Went to El Dorado to pick up a part for Well # 5.

Electric Dept.

Banner holders.

Locates

Several outages.

Safety meetings.

Service Rebuild.

Moved the downtown sound system and rewired it.

Delivered banner holders to Attica and Harper.

Replaced a breaker at the Municipal Hall.

Garrett and Daniel attended training at KMU in McPherson on transformer connections.

Power Plant

Power Plant Report/ Lake 12/15/23

Got the garage roof all finished up on top with all new metal roof at 71C.

Working on the inside of garage where the ceiling was damaged by water and trying to figure out the best way to fix the wiring problems we discovered while working on the rotten ceiling.

Tate has been working on some painting on the inside of the house in the bathroom area.

The boys trimmed the tree row along the road at the power plant to clear out the path along the road.

TM & HT have worked on many fire trucks and other things at the station.

Did some oil changes on our trucks and police cars.

Worked on the heater at the lake shop with no luck keeping it running so we replaced it with a reliable one.

Worked on the mowers and other equipment at the lake.

Started trimming trees and burning stumps at the lake, hoping to spend more time on getting some groundwork done on some of the holes and low spots.

LB attended a EMP-2 meeting and has been working on the grant funding with Jerry, hope we can wrap this up soon.

Normal everyday work and rounds at the plant and substations.

Water Dept.

12/4-8 rounds worked on dehumidifier, cleaned level transducer at the tank, fixed all of the vacuum leaks on McD's lift station, finished masonry work on the manhole at the old hospital, studied water book with Gary, started reassembling the vulcan press at the sewer plant.

12/11-15 Rounds, finished assembling vulcan press and putting everything back in normal operation, water plant installed a different Pc, worked on well 3 flow meter x2, removed ac's from well houses, fixed a pump malfunction at the sewer ponds, replaced check valve in well 5 (well 5 is up and running), clean High Service house, inventoried Lift station repair parts.