

City of Anthony Transformer and OCR Quote Request

Pole mounted transformers 15 KVA and smaller **MUST HAVE** Flipper/Arrestor mounting provisions

Pole mounted transformers must have double primary top mounted bushings

All transformers **MUST HAVE** external tap changers excluding 5 KVA transformers

Transformers

QTY	Category	Phase	KVA	HV	LV
10	Pole Mount	1	5	7200/12470Y	120/240
5	Pole Mount	1	10	7200/12470Y	120/240

OCR's

QTY	Seq. Cord.	Phase	Amps	Type	Lockout	Voltage	
6	2A 2B	1	70	(KYLE) L	1-Shot	7200/12470	Oil Filled
9	2A 2B	1	35	(KYLE) L	1-Shot	7200/12470	Oil Filled
6	2A 2B	1	35	(KYLE) H	1-Shot	7200/12470	Oil Filled
2	2A 2B	1	25	(KYLE) 4-H	1-Shot	7200/12470	Oil Filled