

Department Reports
10.3.2025

ELECTRIC DISTRIBUTION

Tickets, locates

Replaced street lighting on light list

Had 2 meters in rural not reading, cause from blown fuses.

Report of outage at 59 S.W. 20 Rd. Unknown cause.

Moved electric service 2.5 miles west and 2 miles south.

Replaced meter socket at 128 W. Main

Done maintenance in west rural.

Went over locations for lake bathroom and camping stalls.

Attended COW Day at Chaparral.

Took down Christmas lights at Petunia's. (Broken light clips)

Cleaned trucks.

Turn on/off orders

POWER PLANT

Rounds

STREET

Mowing town

Sweeping

Fixed alleys on N Kansas, S Bluff and N Springfield

Replaced road sign at the lake

Mowed Sunrise

Weed spraying

Helped with C.O.W. days at Chaparral

WATER/WASTEWATER

Rounds, tickets, locates