



## THE CITY OF ANTHONY

124 S. Bluff / P. O. Box 504  
ANTHONY, KANSAS 67003

(620) 842-5434  
FAX (620) 842-5753  
[www.anthonykansas.org](http://www.anthonykansas.org)

June 3, 2022

KDHE  
Bureau of Environmental Field Services  
Division of Environment  
300 West Douglas, Suite 700  
Wichita, KS 67202-2921

RE: Anthony Lake Onsite Wastewater Treatment Facility  
Kansas WPC Permit No: M-AR04-NO04


Dear Amanda Smyth,

In response to the required actions as per the inspection compliance report dated May 12, 2022, the following corrections have been made:

1. The city will perform quarterly as well as annual inspections on the Anthony Lake Onsite Wastewater Cluster Systems as required. The criteria for each inspection type is outlined on the attached log sheet which the city will continue to use.

Please let us know if we are missing an inspection criterion or any other additions to this action in order to achieve compliance with this report.

Respectfully,



Cyndra Kastens  
Terry Stark

QUARTERLY INSPECTIONS	Wet or Muddy	Excessive Lush Vegetation (Lat Lines)	Water Surface Elevation	Notes	Inspection Date
UNUSUAL CONDITIONS					
Septic Tank					
Vent, clean-out or d-box					
Lateral Lines					
Inspection Port in Septic Tank					
YEARLY INSPECTIONS					
Sludge & Scum Accumulation					
Septic Tank Baffles or tees					
Septic Tank Observation Ports					
Effluent Filters & Clean					
Structural Integrity of Tanks					