

DEPARTMENTS REPORT

September 3, 2024

POWER PLANT

Miscellaneous operator's duties i.e. checking sub, doing paperwork, general cleaning and duties. Mowing, weed eating, spraying and general maintenance at plant and lake.

Substation maintenance - took care of sump pump at sub.

Arranged for #4 to be delivered to Misak.

Ordered Grasshopper Mower for Lake.

Repaired merry-go-round at lake, fixed picnic table bench in camp site A, with assistance from street dept.

Getting Lake ready for Holiday.

Retro fitting a few light fixtures in plant engine room to LED lighting.

Helped in office, did various reports.

Asked line crew to remark underground line at plant for upcoming core sample.

ELECTRIC DISTRIBUTION

Hung 42 Door Knockers

Report of outage at 219 S. Franklin. Cause from Roofing Co.

Report of outage at 462 SE 40 Ave. Cause from broken primary strand.

Removed fuse box and installed breaker box at the Airport Light Vault.

Repaired pole top 4 miles east and 6.5 miles south.

Done Non-Pay Turn Off's

Trimmed tree on N. Springfield.

Replaced A5 pole 2.3 miles west.

Quoted new services.

Locates

Just Read Orders

Work Orders

Replaced lights on the light list.

WATER/WASTEWATER

Rounds

Sewer cleaning

Locates

Clean shop

Water main repair

Working on department operational plan

Mortuary lift station repair

Water tower lift station phase monitor replaced

Resin was replaced.