

DEPARTMENT REPORT

October 1, 2024

STREET

Regular mowing town & airport
Regular grading town & lake
Removed tile at City office drop box
Ran street sweeper
Assisted Circle C during chip seal (moved vehicles)
Prepared ball field area for Circus

WATER/WASTEWATER

Rounds
Sewer cleaning
Rebuilt valve in high service
Worked on the transducer on pump 2
Water leak repairs 800 N Jennings
Rebuilt pigtail at 400 N. Anthony
Sewer cleaning (down to just the west side of LL&G)
Lead sampling

ELECTRIC DISTRIBUTION

Repaired neutral strand and cut limbs off line 1 mile north and 1 mile east.
Finished new electric service for Chris Ferguson 5 miles east and 3.5 miles south.
Finished pulling wire for the AWOS system at the airport.
Reported outage at the North Coop. Cause was a bad connector.
Report of outage 8.5 east and 1 south. Cause was a blown trans. Fuse.
Report of outage N.E. rural. Cause was from limbs on primary line.
Had Altec work on #7 Digger Derick. Replaced function valve.
Repaired street lights.
Turn On/Off Orders
Just Read Orders
Locates

ELECTRIC PRODUCTION

LB has been back on light duty for two weeks now and is trying to get things figured out, I do want to thank NC and my crew for carrying the load while I was home healing up my body. I also want to thank Cyndra K. for helping me through my struggles at having to stay off work and the other wonderful people we have on our crews for checking on me and helping in so many ways. I also want to thank the commissioners who reached out and checked on my well being, It's a great privilege to work alongside such people. Thank You.

We have been trying to help DB at the lake when we can since he's a one man show now. All of our units have been tested / ran for KMEA / SPP integrated market systems, so we are good on capacity reliability for another year.

We have been doing some maintenance in and around the engine rooms, working on some old oil barrels that need cleaned up.

We got some much-needed moisture so the mowing just keeps on continuing.

LB attended the EMP-2 meeting in McPherson and had some great conversations with other people and the projects they are working on.

I had an employee give notice of leaving so we will be working on replacing the employee in the future.

Normal everyday rounds and work at the power plant, substations and lake.

Thank You

Larry Berry

Power Plant Superintendent / Lake