

**APPLE VALLEY
ORDINANCE O-2023-05**

NOW THEREFORE, be it ordained by the Council of the Apple Valley, in the State of Utah, as follows:

SECTION 1: **AMENDMENT** “11.08.080 Water” of the Apple Valley Subdivisions is hereby *amended* as follows:

BEFORE AMENDMENT

11.08.080 Water

- A. All subdivisions shall have a supply of culinary water available to each lot in the subdivision.
- B. All water to all lots, shall be supplied by the Big Plains Water and Sewer Special Service District, unless otherwise approved by them.
- C. Minimum Water Pressure. At all lots in Town the water pressure shall meet the following minimum water pressures at points of connection:
 - 1. 20 psi during conditions of fire flows and fire demand experienced during peak day demand.
 - 2. 30 psi during peak instantaneous demand.
 - 3. 40 psi during peak day demand.

If Big Plains Water and Sewer Special Service District is unable to meet these minimum required water pressures, with the existing resources available to them, the subdivision cannot be approved, unless the developer is able to provide the needed resources (storage tanks, etc.) to solve the problem to Big Plains Water and Sewer Special Service District’s satisfaction.

An application for a zone change or preliminary plat must include a letter from the governing water authority (Big Plains Water and Sewer Special Service District, etc.) confirming the following:

- A. That it is feasible to provide water to the property and
- B. That water sufficient to support the property is available.

AFTER AMENDMENT

11.08.080 Water

- A. All subdivisions shall have a supply of culinary water available to each lot in the subdivision.
- B. All water to all lots, shall be supplied by the Big Plains Water ~~and Sewer~~ Special Service District, unless otherwise approved by them.

- C. Minimum Water Pressure. At all lots in Town the water pressure shall meet the following minimum water pressures at points of connection:
1. 20 psi during conditions of fire flows and fire demand experienced during peak day demand.
 2. 30 psi during peak instantaneous demand.
 3. 40 psi during peak day demand.

If Big Plains Water ~~and Sewer~~ Special Service District is unable to meet these minimum required water pressures, with the existing resources available to them, the subdivision cannot be approved, unless the developer is able to provide the needed resources (storage tanks, etc.) to solve the problem to Big Plains Water ~~and Sewer~~ Special Service District's satisfaction.

An application for a zone change or preliminary plat must include a letter from the governing water authority (Big Plains Water ~~and Sewer~~ Special Service District, ~~etc.~~) confirming the following:

- A. That it is feasible to provide water to the property and
- B. That water sufficient to support the property is available.

SECTION 2: REPEALER CLAUSE All ordinances or resolutions or parts thereof, which are in conflict herewith, are hereby repealed.

SECTION 3: SEVERABILITY CLAUSE Should any part or provision of this Ordinance be declared by the courts to be unconstitutional or invalid, such decision shall not affect the validity of the Ordinances a whole or any part thereof other than the part so declared to be unconstitutional or invalid.

SECTION 4: EFFECTIVE DATE This Ordinance shall be in full force and effect from January 18, 2023.

PASSED AND ADOPTED BY THE APPLE VALLEY COUNCIL

_____.

	AYE	NAY	ABSENT	ABSTAIN
Mayor Frank Lindhardt	_____	_____	_____	_____
Council Member Andy McGinnis	_____	_____	_____	_____
Council Member Barratt Nielson	_____	_____	_____	_____
Council Member Kevin Sair	_____	_____	_____	_____
Council Member Robin Whitmore	_____	_____	_____	_____

Attest

Presiding Officer

Jenna Vizcardo, Town Clerk, Apple
Valley

Frank Lindhardt, Mayor,, Apple
Valley