

**APPLE VALLEY
ORDINANCE O-2022-09**

NOW THEREFORE, be it ordained by the Council of the Apple Valley, in the State of Utah, as follows:

SECTION 1: **AMENDMENT** “11.08.080 Water” of the Apple Valley Subdivisions is hereby *amended* as follows:

BEFORE AMENDMENT

11.08.080 Water

- A. All subdivisions shall have a supply of culinary water available to each lot in the subdivision.
- B. All water to all lots, shall be supplied by the Big Plains Water and Sewer Special Service District, unless otherwise approved by them.
- C. Minimum Water Pressure. At all lots in Town the water pressure shall meet the following minimum water pressures at points of connection:
 - 1. 20 psi during conditions of fire flows and fire demand experienced during peak day demand.
 - 2. 30 psi during peak instantaneous demand.
 - 3. 40 psi during peak day demand.

If Big Plains Water and Sewer Special Service District is unable to meet these minimum required water pressures, with the existing resources available to them, the subdivision cannot be approved, unless the developer is able to provide the needed resources (storage tanks, etc.) to solve the problem to Big Plains Water and Sewer Special Service District’s satisfaction.

AFTER AMENDMENT

11.08.080 Water

- A. All subdivisions shall have a supply of culinary water available to each lot in the subdivision.
- B. All water to all lots, shall be supplied by the Big Plains Water and Sewer Special Service District, unless otherwise approved by them.
- C. Minimum Water Pressure. At all lots in Town the water pressure shall meet the following minimum water pressures at points of connection:
 - 1. 20 psi during conditions of fire flows and fire demand experienced during peak day demand.
 - 2. 30 psi during peak instantaneous demand.
 - 3. 40 psi during peak day demand.

If Big Plains Water and Sewer Special Service District is unable to meet these

minimum required water pressures, with the existing resources available to them, the subdivision cannot be approved, unless the developer is able to provide the needed resources (storage tanks, etc.) to solve the problem to Big Plains Water and Sewer Special Service District's satisfaction.

An application for a zone change or preliminary plat must include a letter from the governing water authority (Big Plains Water and Sewer Special Service District, etc.) confirming the following:

- A. That it is feasible to provide water to the property and
- B. That water sufficient to support the property is available.

PASSED AND ADOPTED BY THE APPLE VALLEY COUNCIL

_____.

	AYE	NAY	ABSENT	ABSTAIN
Council Member / Mayor Pro Tem Kevin Sair	_____	_____	_____	_____
Council Member Robin Whitmore	_____	_____	_____	_____
Council Member Andy McGinnis	_____	_____	_____	_____
Council Member Barratt Nielson	_____	_____	_____	_____
Attest				

Jenna Vizcardo, Town Clerk, Apple Valley

Kevin Sair, Council Member / Mayor Pro Tem Apple Valley