

WALNUT PARK
Madison Ave. and U.S. 77
Fall 2006

<u>LOCATION / DEFICIENCY</u>	<u>ADAAG REQUIREMENT(S)</u>	L = Low M = Medium H = High <u>PRIORIT</u>	<u>Barrier Removal Target Date & Notes</u>	<u>RECOMMENDATIONS</u>
<p><u>PARK FEATURES</u></p> <p>Parking:</p> <ul style="list-style-type: none"> - No designated parking exists (surfaces are uneven grass and gravel). <p>Accessible routes:</p> <ul style="list-style-type: none"> - Amenities such as fixed picnic tables, BBQ grills and restrooms are on routes of uneven grass (picture). <p>Restrooms:</p> <ul style="list-style-type: none"> - Signage is located off the route to the restrooms (picture). - Side grab bars are mounted at angles and thus one end is 30" high to gripping surface (picture). - Grab bars have 3" between wall and bar (picture). 	<p>Minimum of 1 "van accessible" space with an access aisle at least 96" wide. Parking spaces and access aisles shall be level with surface slopes not exceeding 1:50 or 2% in all directions (4.1.2(5)(b) and 4.6.3).</p> <p>At least one accessible route shall connect accessible buildings, facilities, elements, and spaces that are on the same site. Ground and floor surfaces along accessible routes and in accessible rooms and spaces including floors, walks, ramps, stairs, and curb ramps, shall be stable, firm, slip-resistant (4.3.2 and 4.5.2).</p> <p>See recommendation.</p> <p>All grab bars shall be located 33" to 36" above the finish floor (Figure 30(c)).</p> <p>The space between the wall and the grab bar shall be 1 1/2" (4.26.2).</p>	<p style="text-align: center;">H</p> <p style="text-align: center;">H</p> <p style="text-align: center;">M+</p> <p style="text-align: center;">M</p> <p style="text-align: center;">M</p>		<p>We recommend modifying one area close to restrooms to have accessible amenities on connecting accessible routes. Examples of such amenities include: parking, picnic areas, BBQ grill, parking, etc.</p> <p>Add additional signage to front wall near each entrance on sidewalk side.</p>

<u>LOCATION / DEFICIENCY</u>	<u>ADAAG REQUIREMENT(S)</u>	<u>PRIORITY</u> L = Low M = Medium H = High	Barrier Removal Target Date & <u>Notes</u>	<u>RECOMMENDATIONS</u>
<ul style="list-style-type: none"> - Toilet paper dispensers are mounted above side grab bars (picture). 	<p>The toilet paper dispenser shall be mounted below the grab bar at a minimum height of 19" (4.16.6).</p>	L+		



Amenities such as fixed picnic tables and BBQ grills are not on accessible routes.



The restrooms are not on an accessible route. Signage is located off the route to the entrance.



Restrooms have toilet paper dispensers mounted above side grab bars and 3" between bars and wall (yellow arrow).