



Engineer Committee Meeting

Meeting Date: 4/28/2026

Sodium Hypochlorite Storage Tanks

Department:	4416
Presenter:	Wes Byne
Caption:	Emergency procurement purchase of 2- tanks for Sodium Hypochlorite Storage from Carl Eric Johnson.
Background:	The 2 tanks are for the Highland Ave. Water Treatment Plant 2 of the 12.5% Sodium Hypochlorite tanks has developed a cracks and has caused the storage capacity to be cut by 2/3, the old tanks are over 8 years old and are starting develop leaks.
Analysis:	“This is an emergency request, and a PO was requested due to the time sensitiveness of the repair. Therefore, this agenda is for your information only”.
Financial Impact:	\$ 101,838.00 is the impact and there are funds available
Alternatives:	None Recommended.
Recommendation:	Recommendation is to receive the information about the emergency procurement from Carl Eric Johnson Inc. to purchase these tanks.
Funds are available in the following accounts:	506-04-3520-5425110
<u>REVIEWED AND APPROVED BY:</u>	N/A