



Engineer Service Committee

Meeting Date: 5/12/2026

#7 Rwps Diesel Engine

Department:	4416- Utilities
Presenter:	Wes Byne
Caption:	Motion to Approve Sole Source Service of #7 RWPS Diesel Repair to W.W. Williams in the amount \$83,160.90
Background:	There are three diesel pumps at the canal pumping station. One of the units, named the #7 diesel, was having issues staying running and has developed oil and water leaks. The vendor has recommended service be performed on it to restore the pump to normal operating service.
Analysis:	“This is an Sole-Source request, and a PO was requested due to the time sensitiveness of the repair. Therefore, this agenda is for your information only”.
Financial Impact:	This is a cost Of \$83,160.90 for the Service of #7 Rwps Diesel
Alternatives:	To not have the service done will limit our backup capacity.
Recommendation:	Recommendation is to award the Emergency Service to W.W. Williams
Funds are available in the following accounts:	506-04-3580-5421110
<u>REVIEWED AND APPROVED BY:</u>	N/A