



Meeting Name

Meeting Date: April 9, 2024

Approve Emergency Repair of Backup Generator

| | |
|---|--|
| Department: | Utilities |
| Presenter: | Wes Byne |
| Caption: | Approve Emergency Procurement to Repair Backup Generator |
| Background: | The backup generator that serves our Pistol Range Road Raw Water Pumping Station has developed radiator issues that need to be resolved by replacing the existing radiators. This unit has been in operation since 2005 and backs up our station which provides raw water to the N. Max Hicks Water Treatment Plant. |
| Analysis: | We requested an evaluation of the system by Cummins Sales & Services, the manufacturer's representative, to determine if a repair is feasible. They have determined that replacement of the radiator is needed because the unit has reached the end of its useful life and needs to be replaced to restore operation. We requested and received the attached proposal for this work. Proper functioning of this system is critical to our ability to assure a reliable source of water is available for use as needed. |
| Financial Impact: | \$92,456.29 from budgeted funds |
| Alternatives: | None Recommended |
| Recommendation: | Approve emergency procurement of repair services for this critical item. |
| Funds are available in the following accounts: | 506-04-3540/54-25110 |
| <u>REVIEWED AND APPROVED BY:</u> | N/A |