



Public.Service.Committee.Meeting

Meeting Date: 03/10/26

Augusta Regional Airport (AGS) – Emergency purchase for direct boring
and installation of new conduit.

- Department:** Augusta Regional Airport (AGS)
- Presenter:** Herbert L. Judon, Jr., Airport Executive Director
- Caption:** Augusta Regional Airport (AGS) – Receive as information emergency request for Trinity Electrical Services, Inc. in the amount of \$56,372 for direct boring and installation of new conduit.
- Background:** In the last year, the Augusta Regional Airport (AGS) has had recurring problems with three of our systems: the rotating beacon, wind cone and more recently the Automated Surface Observing System (ASOS). After months of investigation, it was finally discovered the conduits and wires to these systems, that feed into the electrical vault, at some point had been damaged.
- These systems are critical supplemental navigational and weather reporting components. This work will ensure day-to-day operational efficiency of the systems as well as ensuring preparedness for the upcoming Masters Golf Tournament. Lines and conduits must be completely replaced to prevent further interruptions and/or degradation to the abovementioned systems.
- The work will primarily consist of direct boring and installing new conduits and lines. The total for this repair is \$56,372. There was a more expensive option to incase these conduits in concrete for added protection. However, our recommendation is the less expensive option.
- Analysis:** Trinity Electrical Services, Inc. is currently mobilized on site and able to execute this emergency work prior to Masters® Tournament week.
- Financial Impact:** This payment will come from Airport Enterprise Funds.

Alternatives: N/A

Recommendation: Receive as information emergency purchase for Trinity Electrical Services, Inc. in the amount of \$56,372 for direct boring and installation of new conduit.

Funds are available in the following accounts: 551081113-5223110

REVIEWED AND APPROVED BY: N/A