



Administrative Services Committee

Meeting Date: 11/14/2023

Emergency – Richmond County Sheriff’s Office Chilled Water Coil

Department:	Central Services Department
Presenter:	Ron Lampkin
Caption:	Receive as information the emergency request for the replacement of a chilled water coil for AHU -1 at the Richmond County Sheriff’s Office in the amount of \$40,717.78 by Trane US, Inc.
Background:	AHU -1 that serves the first floor of the Sheriff’s building is currently out of service due to a faulty chilled water coil. The failure of this unit, coupled with the outside temperature, is causing temperature to increase. It is imperative that the replacement of the coil takes place to properly provide the conditioned air required to prevent the threat to public health.
Analysis:	Trane will perform the replacement of the coil at the RCSO facility.
Financial Impact:	\$40,717.78; Capital GL: 272-01-6210 / 54.12110
Alternatives:	A – Receive as information B – Do not receive as information
Recommendation:	Receive as information the emergency request for the replacement of a chilled water coil for AHU -1 at the Richmond County Sheriff’s Office in the amount of \$40,717.78 by Trane US, Inc.
Funds are available in the following accounts:	Capital; GL: 272-01-6210 / 54.12110