

Engineer Service Meeting

Meeting Date: 04/29/2025 #6 & #7 Basin Inlet Valves

Department: Utilities - 4416

Presenter: Wes Byne

Caption: Approve Emergency Procurement of 30" valves for Highland WTP.

Background: The 30" inch inlet valves to basin's 6 & 7 at the Highland Water Treatment

plant are not properly seating and do not seal off water flow. This negatively

impacts operations and our ability to repair and clean individual

sedimentation basins. These valves typically have a very long lead time, and usually require at least 26 weeks to procure. A local supply house, Fortiline, has 2 of them on the shelf and since they are already here in the USA they

are not subject to the tariffs that will be affecting new purchases.

.

Analysis: This is an emergency request, and a PO was already requested due to

the time sensitiveness of the repair. Therefore, this agenda is for

ratification of funds.

Financial Impact: \$32,094.00 from budgeted funds

Alternatives: None Recommended

Recommendation: Approve Purchase of Services for this Critical Infrastructure.

Funds are available in 506-04-3520-5421110

the following accounts:

REVIEWED AND N/A

APPROVED BY: