



Administrative Services Committee

Meeting Date: 4/16/2024

Emergency – Charles B. Webster Detention Center Fire Alarm

Department:	Central Services Department
Presenter:	Ron Lampkin
Caption:	Receive as information the emergency request for fire alarm software update and device replacement plan at Charles B. Webster Detention Center in the amount of \$36,500.00 to Southeastern System Technologies.
Background:	CBWDC fire alarm system requires a software upgrade to bring it to compliance. This upgrade will allow Southeastern to address the non-functioning alarm devices and develop a plan to perform the required replacements. Failure to upgrade the system poses as a significant safety risk to inmates and employees in the event of a fire.
Analysis:	Southeastern System Technologies is currently performing corresponding corrective work.
Financial Impact:	<p>\$36,500.00</p> <p>GL: 272-01-6210 / 53.19130</p>
Alternatives:	<p>A – Receive as information</p> <p>B – Do not receive as information</p>
Recommendation:	Receive as information the emergency request for fire alarm software update and device replacement plan at Charles B. Webster Detention Center in the amount of \$36,500.00 to Southeastern System Technologies.
Funds are available in the following accounts:	<p>\$36,500.00</p> <p>GL: 272-01-6210 / 53.19130</p>