



Commission Meeting

March 29, 2023

Emergency – Charles B. Webster Detention Center Chilled Water Coil

Department:	Central Services Department
Presenter:	Ron Lampkin
Caption:	Receive as information the emergency request for the replacement of a chilled water coil at Charles B. Webster Detention Center in the amount of \$26,715.00 by Trane US, Inc.
Background:	One of the Charles B. Webster Detention Center HVAC units (AHU 7E) is currently out of service due to a faulty chilled water coil. This unit directly serves one of the inmate pods. The failure of this unit, coupled with the outside temperature, is causing the pod temperature to increase. It is imperative that the replacement of the coil takes place to properly provide the conditioned air required to prevent the threat to public health.
Analysis:	Trane will perform the replacement of the coil at the CBWDC facility.
Financial Impact:	<p>\$26,715.00; SPLOST</p> <p>GL: 330-05-1120 / 54.13120</p> <p>JL: 222-05-8101 / 54.13120</p>
Alternatives:	<p>A – Receive as information</p> <p>B – Do not receive as information</p>
Recommendation:	Receive as information the emergency request for the replacement of a chilled water coil at Charles B. Webster Detention Center in the amount of \$26,715.00 by Trane US, Inc.
Funds are available in the following accounts:	SPLOST; GL: 330-05-1120 / 54.13120