



Engineering Service Committee

Meeting Date: 11/23/2025

Recommend Approve Bid 25-182 Generator Controls Upgrade for Both Surface Water Treatment Plants – Cummins Inc.

| | |
|---|---|
| Department: | Utilities Department |
| Presenter: | Wes Byne |
| Caption: | Recommend approval of Bid 25-182 for Upgrading Generator Controls for Both Surface water treatment plants to Cummins Inc. |
| Background: | The existing generator controls are 21 years old. The existing units are nearing their service life, and obtaining parts and software upgrades is getting very expensive. |
| Analysis: | This was procured using standard Augusta Procurement Department guidelines. Cummins Inc. was the only responsive Bidder |
| Financial Impact: | \$ 773,334.60 is the impact and there are funds available in operating capital |
| Alternatives: | No alternative is presented. |
| Recommendation: | Approve this Service to Cummins Inc. |
| Funds are available in the following accounts: | 506043520-5421110 |
| <u>REVIEWED AND APPROVED BY:</u> | N/A |