



## Engineering Service Committee

Meeting Date: 11/25/2025

Sole Source for Englewood Electric Medium Voltage Circuit Protectors

---

|   |   |
|---|---|
| <b>Department:</b>                                    | Utilities Department  |
| <b>Presenter:</b>                                     | Wes Byne  |
| <b>Caption:</b>                                       | Sole Source for Englewood Electric Medium Voltage Circuit Protectors  |
| <b>Background:</b>                                    | Englewood Electric proposal to do the upgrade needed at Hicks Plant for the MV Starter Motor Protection Relay. The work will consist of installing needed parts and engineering to migrate the motor protection relay for the motor starters. This will serve to upgrade the plant's control and monitoring systems. This upgrade is needed from this source as they are the sole source provider for Allen Bradley for our municipality. |
| <b>Analysis:</b>                                      | The current MV Circuit protection is nearing end of life and these are needed to help trip the 4160 Vac Breakers in case of a Fault   |
| <b>Financial Impact:</b>                              | \$ 85,135.00 is the impact and there are funds available  |
| <b>Alternatives:</b>                                  | No Alternatives.  |
| <b>Recommendation:</b>                                | Approve this Service and Equipment for Englewood Electric   |
| <b>Funds are available in the following accounts:</b> | 506-04-3540-5421110.  |
| <b><u>REVIEWED AND APPROVED BY:</u></b>               | N/A   |