



Engineering Services Committee

Meeting Date: 7/14/2026

Lakeview Lift Station Submersible Pump

Department:	4416- Utilities
Presenter:	Wes Byne
Caption:	Motion to Approve Sole Source of Submersible Lift Station Pump for Lakeview Terrace on Ft. Gordon in the amount \$59,891.00
Background:	Lakeview Lift Station has been in service for 22 Years, and the current pump has been repaired several times but now has developed a hole in the cooling jacket and this station would be on one pump.
Analysis:	“This is a Sole Source request, and a PO was requested due to the time sensitiveness of the repair. Therefore, this agenda is for your information only”.
Financial Impact:	This is a cost \$59,891.00 purchase of new submersible pump
Alternatives:	No Alternatives.
Recommendation:	Recommendation is to award the Sole Source Purchase to Templeton and Associates
Funds are available in the following accounts:	506-04-3430-5421110
<u>REVIEWED AND APPROVED BY:</u>	N/A