



Commission Meeting

Meeting Date: 02/03/2026

Emergency Procurement - 30 Inch Valves for Highland Treatment Plant

Department:	Utilities Department
Presenter:	Wes Byne
Caption:	Receive as information the emergency purchase replacement of 30 inch Valves for Basins 4 & 5 at the Highland Ave Treatment Plant.
Background:	The Inlet valves are leaking by and causing the basins to short cycle and hurt production Run Times.
Analysis:	This is an emergency request, and a PO was requested due to the time sensitiveness of the repair. Therefore, this agenda is for your information only.
Financial Impact:	\$ 36,000.00 is the impact and there are funds available
Alternatives:	No Alternative as equipment has already been rented.
Recommendation:	Receive as information the emergency purchase from Fortiline Waterworks
Funds are available in the following accounts:	506-04-3520-5421110
<u>REVIEWED AND APPROVED BY:</u>	N/A