



Engineering Committee Meeting

Meeting Date: 9/30/2025

Sodium Hypochlorite Storage Tanks

Department:	Utilities - 4416/A
Presenter:	Wes Byne
Caption:	Approve an emergency purchase of 2- tanks for Sodium Hypochlorite Storage.
Background:	This is a request for the purchase of 2 chemical storage tanks. The first tank is for the Highland Ave. Water Treatment Plant, where one of the 12.5% Sodium Hypochlorite tanks has developed a crack and has caused the storage capacity to be cut by 1/3. The second tank is for Morgan Road Booster Station and is needed to facilitate chlorination as this take services Ft. Gordon. This pump station has chlorination system failure, so the intent is to convert it into bleach. This station is being put back in service to facilitate more storage for Ft. Gordon and the Tobacco Rd corridor.
Analysis:	This is a critical storage of disinfection to keep us within EPD guidelines.
Financial Impact:	\$ 56,060.00 is the impact and there are funds available
Alternatives:	None Recommended
Recommendation:	Recommendation is to receive the information the emergency procurement from Carl Eric Johnson Inc. to purchase these tanks.
Funds are available in the following accounts:	506-04-3520-5425110
<u>REVIEWED AND APPROVED BY:</u>	N/A