

Public.Service.Committee.Meeting

Meeting Date: 04/15/2025

Airport Fire Alarm Computer Upgrade

Department:	Augusta Regional Airport
Presenter:	Herbert L. Judon, Jr., Airport Executive Director
Caption:	Motion to approve Upgrade of Airport Fire Alarm Computer System
Background:	Fire Alarms across the airport report to a central computer (Truesite Workstation- TSW) located in the Marshall's Operation Center (MOC). The computer provides dispatch information to ARFF for response through the MOC operator. Updates to building fire alarms and new facilities have outpaced the computer. The computer is original to the building, and it is no longer capable of growing with the airport
Analysis:	The system is proprietary to Simplex (Johnson Control Inc) and needs to be upgraded to provide fast efficient information to aid in Fire Department response to emergencies.
Financial Impact:	\$80,000 was budgeted this year for the upgrade to the Truesite Workstation (TSW) computer.
	This Software has been budgeted and will be funded by the Airport Enterprise Fund
	Account Number: 551-08-1207: 54.21110
Alternatives:	N/A
Recommendation:	Approve Upgrade of Airport Fire Alarm Computer System
Funds are available in th following accounts:	ne 551-08-1207: 54.21110
<u>REVIEWED AND</u> APPROVED BY:	N/A