



## Administrative Services Committee

Meeting Date: Tuesday, March 10, 2026

Emergency – Richmond County Sheriff’s Office Evidence Building Gas Pack Unit

---

**Department:** Central Services Department

**Presenter:** Horace Green

**Caption:** Receive as information the emergency request for the replacement of the gas pack unit at the Richmond County Sheriff’s Office Evidence Building in the amount of \$25,000.00 by GCT Industrial, LLC.

**Background:** Atlanta Gas Company responded to the RCSO Evidence Building and determined that the gas pack unit was leaking CO2. Gas has been shut off until the unit could be assessed. After an assessment was performed on the unit, it was found that the gas pack unit would require a complete replacement. Due to the nature of this issue, the unit is unable to properly regulate temperatures within the facility. As the evidence must remain in a temperature-controlled environment, it is imperative that this situation was addressed as soon as possible to prevent any potential impact on stored evidence. GCT Industrial was deemed qualified to make the replacement of the gas pack unit.

**Analysis:** GCT Industrial, LLC performed the corresponding replacement work.

**Financial Impact:** \$25,000.00; 101016216/53.19130

**Alternatives:** A – Receive as information  
B – Do not receive as information

**Recommendation:** Receive as information the emergency request for the replacement of the gas pack unit at the Richmond County Sheriff’s Office Evidence Building in the amount of \$25,000.00 by GCT Industrial, LLC.

**Funds are available in the following accounts:** \$25,000.00; 101016216/53.19130