



## **Administrative Services Committee**

Meeting Date: 1/31/2023

Emergency – Craig Houghton Water Mitigation

---

<b>Department:</b>	Central Services Department
<b>Presenter:</b>	Ron Lampkin
<b>Caption:</b>	Receive as information the emergency request for water mitigation and drying of structure at Craig Houghton in the amount of \$64,231.71 by ServPro of Augusta.
<b>Background:</b>	Due to the low temperature experienced during the 2022 Christmas weekend, the pipes that provide water to the fire sprinkler system became frozen and burst, causing leaks throughout the building. These leaks caused water damage to the structure and could potentially cause mold. It is imperative that the remediation process takes place to preserve the integrity of the structure.
<b>Analysis:</b>	ServPro of Augusta will perform the mitigation to prevent further damage to the facility.
<b>Financial Impact:</b>	\$64,231.71; GL: 101016223 / 53.19120
<b>Alternatives:</b>	A – Receive as information B – Do not receive as information
<b>Recommendation:</b>	Receive as information the emergency request for water mitigation and drying of structure at Craig Houghton in the amount of \$64,231.71 by ServPro of Augusta.
<b>Funds are available in the following accounts:</b>	GL: 101016223 / 53.19120