



Engineering Committee Meeting

Meeting Date: 9/29/2026

#15 Aux Pump at Highland Plant

Department:	Utilities - 4416
Presenter:	Wes Byne
Caption:	Approve Sole Source Procurement of #15 Aux Pump and Base from Templeton and Assoc.
Background:	The current pump is a diesel driven Peerless pump that is over 40 years old and has failed, we are replacing this pump with a new Peerless Pump.
Analysis:	We request to purchase a new Peerless Pump to resolve this situation as the pumps impellers and casing has failed beyond repair.
Financial Impact:	\$31,900.00 from budgeted funds
Alternatives:	None Recommended
Recommendation:	Approve Purchase of this Critical Infrastructure.
Funds are available in the following accounts:	506-04-3520-5425110
<u>REVIEWED AND APPROVED BY:</u>	N/A