



Engineer Service Meeting

Meeting Date: 12/31/2024

#9 Check Valve

Department:	Utilities - 4416
Presenter:	Wes Byne
Caption:	Approve Emergency Procurement of Check Valve for #9 Turbine
Background:	#9 Turbine is our biggest raw water turbine and pump for supplying raw water to the Highland Ave. Plant, the current check valve has failed which could cause the turbine to damage itself.
Analysis:	We request to purchase a new check valve to resolve this situation as the seats and inner workings of the valve are damaged beyond repair.
Financial Impact:	\$47,726.00 from budgeted funds
Alternatives:	None Recommended
Recommendation:	Approve Purchase of this Critical Infrastructure.
Funds are available in the following accounts:	506-04-3580-5425110
<u>REVIEWED AND APPROVED BY:</u>	N/A