



Engineering Services

Meeting Date: 10/31/2023

Ardurra Engineering Services Change Order

Department:	Utilities
Presenter:	Wes Byne
Caption:	Approve additional fees in the amount of \$89,000 to Ardurra Engineering for engineering services to evaluate the JB Messerly Wastewater Treatment Plant.
Background:	AUD is currently experiencing moderate levels of inflow and infiltration after rainfall events, which are causing problems with the primary clarifiers. This scope is to evaluate modifications to the plant to minimize problems that occur in the plant after rainfall events.
Analysis:	This additional scope is required to maintain long-term operation of the plant.
Financial Impact:	Funding in the amount of \$89,000 is available from accounts: 507043420-5212115/82200030-5212115
Alternatives:	No alternatives are recommended.
Recommendation:	AUD recommends that these engineering services with Ardurra Engineering be approved.
Funds are available in the following accounts:	Funds are available in the following accounts: 507043420-5212115/82200030-5212115
<u>REVIEWED AND APPROVED BY:</u>	Wes Byne