

SEC. 2.1.004 EMERGENCY ACCESS AND FIRE LANES

(a) Emergency Access Provisions:

The DRC will review all proposed developments for safe and appropriate access, parking lanes, private streets, driveway access points, and other emergency access items.

(b) Fire Lanes shall meet the standards of the IFC as adopted by the City.

SEC. 2.1.005 DRIVE-THROUGH FACILITIES

(a) Drive-throughs are required to be located in the 2nd or 3rd layer of the lot or located from an alley.

(b) Where allowed, locate and design drive-through facilities shall follow the following criteria:

- (1) Do not locate drive-through facilities to adjacent residential uses.
- (2) Screen vehicular storage areas for drive-through facilities placed on the street side of a building, or any other location that is directly visible from adjacent properties with screen walls, mounding, and/or dense

landscaping at least 3 feet in height at the time of planting.

- A. Provide a minimum vertical clearance of 8 feet for drive-through facilities. Provide a minimum vertical clearance of 10 feet for drive-through facilities that include a passenger-loading zone.

SEC. 2.1.006 PARKING AREAS

(a) Parking Spaces:

- (1) Designed parking spaces and drive aisles locations shall be placed in the 1st, 2nd or 3rd layer of the lot, in accordance with the B³ Code.

(b) Accessible (Handicapped) Parking Spaces:

- (1) Adequate designed accessible parking spaces shall be provided as required by the IBC and designed in accordance with the parking area landscaping.

(c) Parking Landscaping:

- (1) Incorporate parking lot landscaped areas and median in accordance with Section 2.1.002 - Landscape Design in the Private Realm.