



ITEM REPORT CITY COUNCIL

Agenda Date: 3/17/2026
Agenda Section: Consent Agenda

Department Origination: Public Works

Agenda Item: Approve the Quality Flow Systems, Inc. Equipment Proposal in the amount of \$58,650.00 for the Lift Station 18 Control Panel, Pumps, Accessories and Hatches

Approval Required: Simple Majority Vote

BACKGROUND

To assure compatibility of control panel/radio telemetry equipment/operations, pump/impellor type, motor phase/voltage and pump base elbows, the City works with Quality Flow Systems, Inc. to provide a “standardized lift station package”. This minimizes the type and number of spare parts the City maintains to assure timely response to lift station issues and cost-effective maintenance of the 26 sanitary sewer lift stations operated by the City.

WIDSETH requested a quote from Quality Flow Systems, Inc. to supply two pumps, control panel, two aluminum access hatches, pump base elbows, submersible pressure transducer, two backup floats and accessories for the reconstruction of Lift Station No. 18. Attached is an Equipment Proposal from Quality Flow Systems, Inc. in the amount of \$58,650 to supply the necessary components. The pumps and equipment will be provided to the City-selected contractor for installation.

FINANCIAL IMPLICATIONS

Staff provided Finance with a budgetary estimate of \$250,900 for the reconstruction of Lift Station 18 in 2026. With Engineering estimated at \$15,000 and Quality Flow Systems, Inc.’s equipment cost of \$58,650, there will be \$177,250 available in the budget for construction.

STAFF RECOMMENDATIONS

The Utilities Commission and staff recommends approval of Quality Flow Systems, Inc.’s Equipment Proposal in the amount of \$58,650.00.

COUNCIL ACTION REQUESTED

MOTION to approve the Quality Flow Systems, Inc. Equipment Proposal in the amount of \$58,650.00 for Lift Station 18 Control Panel, Pumps, Accessories and Hatches.