



ITEM REPORT UTILITIES COMMISSION

Agenda Date: 5/6/2026
Agenda Section: Information Only

Department Origination: Public Works

Agenda Item: 2025 Lift Station 11 Service Area Smoke Testing

Approval Required: No Action Required

BACKGROUND

Wideth distributed notices and visited property owners during the week of April 6, 2026. Smoke testing began on April 22, 2026, and is expected to be completed by May 1, 2026. To date, five broken cleanouts have been identified, along with internal plumbing issues at a commercial property that is currently being addressed by the property owner. Once smoke testing is completed, a report will be prepared to summarize all the findings.

FINANCIAL IMPLICATIONS

STAFF RECOMMENDATIONS

COUNCIL ACTION REQUESTED