



ITEM REPORT UTILITIES COMMISSION

Agenda Date: 5/6/2026
Agenda Section: Information Only

Department Origination: Public Works

Agenda Item: 2026 Kurita Service Trip Report

Approval Required: No Action Required

BACKGROUND

The two aerators and blower were recently inspected, and the technician's recommendation is to rebuild the blower as it has some end play that needs to be addressed. City staff has requested a quote for a new blower and a rebuild of the existing blower.

FINANCIAL IMPLICATIONS

STAFF RECOMMENDATIONS

COUNCIL ACTION REQUESTED