



## ITEM REPORT UTILITIES COMMISSION

Agenda Date: 3/4/2026  
Agenda Section: Information Only

---

**Department Origination:** Public Works

---

**Agenda Item:** 2026 Thein Well Inspection Report Update

---

**Approval Required:** No Action Required

---

### **BACKGROUND**

The City of Baxter contracts with Thein Well Company (Thein) for yearly inspections of the City's existing six wells and pumps. The six wells were off for 10 hours prior to testing. Static water levels were taken on all six wells prior to running any of them. Wells ran for 20 minutes each for drawdown. Measurements down the well were all taken from top of rim to well. No deficiencies were noted.

### **FINANCIAL IMPLICATIONS**

### **STAFF RECOMMENDATIONS**

### **COUNCIL ACTION REQUESTED**