



ITEM REPORT CITY COUNCIL

Agenda Date: 10/20/2026
Agenda Section: Consent Agenda

Department Origination: Public Works

Agenda Item: Accept the Widseth Technical Memorandum Regarding Coring Results for the 2026 Mill & Overlay Improvements Project

Approval Required: Simple Majority Vote

BACKGROUND

During paving of the Mississippi Meadows Neighborhood, mastic was noticed on the surface of the roadway and the bituminous thickness came into question. The City Engineer and Contracted Project Engineering reviewed the road surface after paving was completed and selected three cores to be taken for evaluation. The attached memo provides a detailed analysis of the cores. In summary, the coring information supported an acceptable pavement thickness and the mastic did not migrate through the new pavement.

FINANCIAL IMPLICATIONS

There are no financial implications at this time.

STAFF RECOMMENDATIONS

The Utilities Commission and staff recommends accepting the Widseth Technical Memorandum regarding Coring Results for the 2026 Mill & Overlay Improvements Project.

COUNCIL ACTION REQUESTED

MOTION to accept the Widseth Technical Memorandum regarding Coring Results for the 2026 Mill & Overlay Improvements Project.