



ITEM REPORT CITY COUNCIL

Agenda Date: 10/20/2026
Agenda Section: Consent Agenda

Department Origination: Public Works

Agenda Item: Accept the Widseth Technical Memorandum regarding the Whiskey Creek Bridge Abutment Concrete Results Evaluation for the Whiskey Creek Bridge Abutment Rehabilitation Project

Approval Required: Simple Majority Vote

BACKGROUND

Change Order #2 modified the final completion date due to low concrete breaks and provided the initial background on the low concrete breaks. Since Change Order #2 was approved, the 28-day concrete breaks have been completed. Widseth has prepared a memo based on the 28-day concrete breaks. This memo provides background information and makes the recommendation to leave the bridge abutments in place. By accepting this Memo, the City agrees the abutments can remain in place and the bridge can be set.

Widseth requested the final 35-day cylinder be pushed to a 56-day break to provide additional cure time. The results of the 56-day break was 4,330 psi exceeding the 4,000 psi minimum requirement.

FINANCIAL IMPLICATIONS

There are no financial implications.

STAFF RECOMMENDATIONS

The Utilities Commission and staff recommends accepting the Widseth Technical Memorandum regarding the Whiskey Creek Bridge Abutment Concrete Results Evaluation.

COUNCIL ACTION REQUESTED

MOTION to Accept the Widseth Technical Memorandum regarding the Whiskey Creek Bridge Abutment Concrete Results Evaluation for the Whiskey Creek Bridge Abutment Rehabilitation Project.