

July, 2026

Monthly Maintenance Report

Maintenance

Checking wells, checking pumps, checking sewer pumps, checking PRV's, working at the cemetery, taking water samples, checking the Little League, checking city parks, checking and servicing vehicles, doing meter turn-ons and turn-offs, checking on plugged sewers, and other customer concerns, checking on the chlorine system.

Projects:

Continued Clearing trees in ditch behind the shop
PRV on Joan St. was exercised- manually switching from the high flow to low flow once a month to exercise each valve
Continued new water and sewer line mapping.
Monsoon season- spent a lot of time working on roads and alleys clearing debris
Started building new rod iron gates for cemetery. Going to extend each side 50 ft.
Normal Park maintenance and trash pick-up around them.
Continued weed control around city.
Worked with DOT to get four 24-inch HDPE pipes to use as culverts for the well crossing where Cameron creek runs through.

Water and Sewer:

Sent monthly chlorine tests to be analyzed, all came back good.
Chlorine Analyzer monthly PM
Repaired 6 water leaks one Main and 5 service lines
4 sewer call outs
3 Sewer preventive maintenance- Routing and jetting man holes throughout the city.

Training/Classes/Special Events:

Two team members were signed up for the 2026 NM Water and Wastewater Central School in Albuquerque NM.