

Monthly Maintenance Report- September 2026

Maintenance

Checking wells, checking pumps, checking sewer pumps, checking PRV's, working at the cemetery, taking water samples, checking the Little League, checking city parks, checking and servicing vehicles, doing meter turn-ons and turn-offs, checking on plugged sewers, and other customer concerns, checking on the chlorine system.

Projects:

With new dump trailer cleaning out yard at shop. Clearing property to the north to expand parking for vehicles and equipment.

PRV on Joan St. was exercised- manually switching from the high flow to low flow once a month to exercise each valve

Continued new water and sewer line mapping.

Spent a lot of time working on roads and alleys clearing debris

Normal Park maintenance and trash pick-up around them.

Continued weed control around city.

Sent out disinfection by product samples out. All samples came back within range for drinking water.

Had 2026 Sanitary Survey and compliance inspection. Compliance officer inspected all 4 water storage tanks, all 7 wells, checked all water sampling results for the year, operation and maintenance plan, distribution sampling plan, emergency response plan, and water flushing plan. No findings or issues were found during this inspection.

Water and Sewer:

Sent monthly chlorine tests to be analyzed, all came back good.

Chlorine Analyzer monthly PM

Repaired 4 water leaks

3 sewer call outs

3 Sewer preventive maintenance- Routing and jetting man holes throughout the city.

Training/Classes/Special Events:

3 maintenance employee currently have the Water Level 1 Certification.

Had Safety meeting with Maintenance and Waste Water groups. Being aware of your surroundings.

Have 3 team members complete application with Certemy and should be testing for water level 1 within the month.

1 team member received recertification for level 1 water.