

**City Council Meeting Report
Wastewater Treatment Plant
Reporting Period: June – July**

Operations Summary

- Hauled remaining sludge to the landfill and submitted a sludge sample for laboratory analysis.
 - Completed and submitted the quarterly discharge report to the state.
 - Unclogged the chlorine injector at the wash water building, restoring normal operation.
-

Maintenance and Repairs

- Sent the backhoe to Bayard Maintenance for air conditioning repair.
 - Dement Electric replaced the No. 5 electric blower motor and is currently rebuilding the associated electrical cabinet.
 - During a pre-driving inspection, a nail was discovered in the dump truck tire; the vehicle was taken to Mike's Tires for repair. New tires have been ordered and will be installed this week.
 - Serviced the air conditioner at the recreational plant and replaced the float. Replacement pads will need to be ordered.
-

Projects and Improvements

- Hands On Environmental has begun work at the recreational plant as scheduled.
-

Call Outs / Emergency Response

- Paul Munoz was called out to check on a scum pump that was not turning off automatically. Phantom power was identified by Dement Electric; no further issues have occurred since.
 - Armando Fletcher responded to a power outage affecting the RAS pumps, blowers, and clarifiers. Panels were reset and operations returned to normal.
 - The security system was not arming remotely. Dement Alarms responded on site and recommended replacing the radio device. The system was power cycled, and the alarm is currently operating normally.
-

Upcoming Work / Notes

- Installation of new dump truck tires will be completed this week.
- Replacement pads for the recreational plant air conditioning unit will be ordered and installed upon arrival.
- Continued coordination with contractors (Dement Electric and Hands On Environmental) to complete ongoing repairs and project work.